

Voltmeter 24 Volt	B000049	11/18 	1
--------------------------	----------------	-----------	---

This manual is related to the following gauges:

A2C60100078	MODULE VOLT 24V VLB
A2C60100079	MODULE VOLT 24V VLW
A2C59512457	VLB Volt 52 24V 32V S DL tc A
A2C59512458	VLB Volt 52 24V 32V S DL rb A
A2C59512459	VLW Volt 52 24V 32V S DL rw A



Safety information

- The product was developed, manufactured and inspected according to the basic safety requirements of EC Guidelines and state-of-the-art technology.
- The instrument is designed for use in grounded vehicles and machines as well as in pleasure boats, including non-classified commercial shipping.
- Use our product only as intended. Use of the product for reasons other than its intended use may lead to personal injury, property damage or environmental damage. Before installation, check the vehicle documentation for vehicle type and any possible special features!
- Use the assembly plan to learn the location of the fuel/hydraulic/ compressed air and electrical lines!
- Note possible modifications to the vehicle, which must be considered during installation!
- To prevent personal injury, property damage or environmental damage, basic knowledge of motor vehicle/shipbuilding electronics and mechanics is required.
- Make sure that the engine cannot start unintentionally during installation!
- Modifications or manipulations to VDO products can affect safety. Consequently, you may not modify or manipulate the product!
- When removing/installing seats, covers, etc., ensure that lines are not damaged and plug-in connections are not loosened!
- Note all data from other installed instruments with volatile electronic memories.

Safety during installation:

- During installation, ensure that the product's components do not affect or limit vehicle functions. Avoid damaging these components!
- Only install undamaged parts in a vehicle!
- During installation, ensure that the product does not impair the field of vision and that it cannot impact the driver's or passenger's head!
- A specialized technician should install the product. If you install the product yourself, wear appropriate work clothing. Do not wear loose clothing, as it may get caught in moving parts. Protect long hair with a hair net.
- When working on the on-board electronics, do not wear metallic or conductive jewelry such as necklaces, bracelets, rings, etc.
- If work on a running engine is required, exercise extreme caution. Wear only appropriate work clothing as you are at risk of personal injury, resulting from being crushed or burned.
- Before beginning, disconnect the negative terminal on the battery, otherwise you risk a short circuit. If the vehicle is supplied by auxiliary batteries, you must also disconnect the negative terminals on these batteries! Short circuits can cause fires, battery explosions and damages to other electronic systems. Please note that when you disconnect the battery, all volatile electronic memories lose their input values and must be reprogrammed.
- If working on gasoline boat motors, let the motor compartment fan run before beginning work.
- Pay attention to how lines and cable harnesses are laid so that you do not drill or saw through them!
- Do not install the product in the mechanical and electrical airbag area!
- Do not drill holes or ports in load-bearing or stabilizing stays or tie bars!
- When working underneath the vehicle, secure it according to the specifications from the vehicle manufacturer.

No smoking! No open fire or lights!







- Note the necessary clearance behind the drill hole or port at the installation location. Required mounting depth: 65 mm.
- Drill small ports; enlarge and complete them, if necessary, using taper milling tools, saber saws, keyhole saws or files. Debur edges. Follow the safety instructions of the tool manufacturer.
- Use only insulated tools, if work is necessary on live parts.
- Use only the multimeter or diode test lamps provided, to measure voltages and currents in the vehicle/machine or boat. Use of conventional test lamps can cause damage to control units or other electronic systems.
- The electrical indicator outputs and cables connected to them must be protected from direct contact and damage. The cables in use must have sufficient insulation and electric strength and the contact points must be safe from touch.
- Use appropriate measures to also protect the electrically conductive parts on the connected consumer from direct contact. Laying metallic, uninsulated cables and contacts is prohibited.





Safety after installation:

- Connect the ground cable tightly to the negative terminal of the battery.
- Reenter/reprogram the volatile electronic memory values.
- Check all functions.
- Use only clean water to clean the components. Note the Ingress Protection (IP) ratings (IEC 60529).

Electrical connection:


- Note cable cross-sectional area!
- Reducing the cable cross-sectional area leads to higher current density, which can cause the cable cross-sectional area in question to heat up!
- When installing electrical cables, use the provided cable ducts and harnesses; however, do not run cables parallel to ignition cables or to cables that lead to large electricity consumers.
- Fasten cables with cable ties or adhesive tape. Do not run cables over moving parts. Do not attach cables to the steering column!
- Ensure that cables are not subject to tensile, compressive or shearing forces.
- If cables are run through drill holes, protect them using rubber sleeves or the like.
- Use only one cable stripper to strip the cable. Adjust the stripper so that stranded wires are not damaged or separated.
- Use only a soft soldering process or commercially available crimp connector to solder new cable connections!
- Make crimp connections with cable crimping pliers only. Follow the safety instructions of the tool manufacturer.
- Insulate exposed stranded wires to prevent short circuits.
- Caution: Risk of short circuit if junctions are faulty or cables are damaged.
- Short circuits in the vehicle network can cause fires, battery explosions and damages to other electronic systems. Consequently, all power supply cable connections must be provided with weldable connectors and be sufficiently insulated.
- Ensure ground connections are sound.
- Faulty connections can cause short circuits. Only connect cables according to the electrical wiring diagram.
- If operating the instrument on power supply units, note that the power supply unit must be stabilized and it must comply with the following standard: DIN EN 61000, Parts 6-1 to 6-4.

Voltmeter 24 Volt		B000049	11/18 GB	2																		
Procedures for installing VDO Viewline instruments																						
1 		Before beginning, turn off the ignition and remove the ignition key. If necessary, remove the main circuit switch.																				
2   • Before beginning, disconnect the negative terminal on the battery, otherwise you risk a short circuit. If the vehicle is supplied by auxiliary batteries, you must also disconnect the negative terminals on these batteries! Short circuits can cause fires, battery explosions and damages to other electronic systems. Please note that when you disconnect the battery, all volatile electronic memories lose their input values and must be reprogrammed.		Disconnect the negative terminal on the battery. Make sure the battery cannot unintentionally restart.																				
3 		If installing the instrument near a magnetic compass, note the magnetic safe distance to the compass.																				
4 		The following rings may be installed as alternatives to the supplied front ring: <table><tr><td>Front ring, flat; black</td><td>A2C5318604001</td></tr><tr><td>Front ring, flat; white</td><td>A2C5318602201</td></tr><tr><td>Front ring, flat; chrome</td><td>A2C5318602301</td></tr><tr><td>Front ring, triangular; black</td><td>A2C5318602401</td></tr><tr><td>Front ring, triangular; white</td><td>A2C5318602501</td></tr><tr><td>Front ring, triangular; chrome</td><td>A2C5318602601</td></tr><tr><td>Front ring, round; black</td><td>A2C5318602701</td></tr><tr><td>Front ring, round; white</td><td>A2C5318602801</td></tr><tr><td>Front ring, round; chrome</td><td>A2C5318602901</td></tr></table>			Front ring, flat; black	A2C5318604001	Front ring, flat; white	A2C5318602201	Front ring, flat; chrome	A2C5318602301	Front ring, triangular; black	A2C5318602401	Front ring, triangular; white	A2C5318602501	Front ring, triangular; chrome	A2C5318602601	Front ring, round; black	A2C5318602701	Front ring, round; white	A2C5318602801	Front ring, round; chrome	A2C5318602901
Front ring, flat; black	A2C5318604001																					
Front ring, flat; white	A2C5318602201																					
Front ring, flat; chrome	A2C5318602301																					
Front ring, triangular; black	A2C5318602401																					
Front ring, triangular; white	A2C5318602501																					
Front ring, triangular; chrome	A2C5318602601																					
Front ring, round; black	A2C5318602701																					
Front ring, round; white	A2C5318602801																					
Front ring, round; chrome	A2C5318602901																					
5 		Place the new front ring on the instrument and press it on until it is flush with the instrument glass.																				
6   • Do not drill holes or ports in load-bearing or stabilizing stays or tie bars! • Note the necessary clearance behind the drill hole or port at the installation location. Required mounting depth: 65 mm. • Drill small ports; enlarge and complete them, if necessary, using taper milling tools, saber saws, keyhole saws or files. Deburr edges. Follow the safety instructions of the tool manufacturer.		Conventional assembly. (Instrument is put into the drill hole from the front). The panel width may be within a range of 0.5 to 20 mm. The drill hole must have a diameter of 53 mm.																				
7 		For 52 mm instruments, the fastening nut can be mounted at position A or B. This allows you to realize various clamping heights. Version A Clamping height 0.5 – 10 mm Version B Clamping height 0.5 – 20 mm A: 0.5... 10 mm B: 0.5... 20 mm																				

Voltmeter 24 Volt		B000049	11/18 GB	3																
8		If the instrument is mounted flush (i.e., from the back so that the instrument glass and the panel form one plane), the front ring must be removed. Press the instrument glass with both thumbs, while at the same time pressing the front ring forward from the instrument with both index fingers. Note the use of a tool in the adjacent figure.																		
9	  • Do not drill holes or ports in load-bearing or stabilizing stays or tie bars! • Note the necessary clearance behind the drill hole or port at the installation location. Required mounting depth: 65 mm. • Drill small ports; enlarge and complete them, if necessary, using taper milling tools, saber saws, keyhole saws or files. Deburr edges. Follow the safety instructions of the tool manufacturer.	Flush assembly The recommended panel thickness is 1.5 to 3 mm. The drill hole must have a diameter of 48.1 mm. Ensure that the installation location is level and has no sharp edges.																		
10		Place the flush mount seal A2C53215640 on the instrument glass. Put the instrument into the drill hole from the back. Adjust the instrument so that the gauge is level and fasten it to the stud bolts on the rear side of the panel, using the flush mount fixing bracket A2C59510864.																		
11		Depending on the configuration, insert the cable into the 8-pin contact enclosure according to the following pin assignment. The contacts must audibly lock into place. <table><tr><td>Pin 1 - Term. 15 - ignition plus 12 V</td><td>Red</td></tr><tr><td>Pin 2 - Term. 31 - ground</td><td>Black</td></tr><tr><td>Pin 3 - unassigned</td><td>Blue/black</td></tr><tr><td>Pin 4 - Term. 30 - steady power</td><td>Brown</td></tr><tr><td>Pin 5 - unassigned</td><td>Green</td></tr><tr><td>Pin 6 - Term. 58 - lighting</td><td>Blue/red</td></tr><tr><td>Pin 7 - warning LED ground</td><td>Yellow/Black</td></tr><tr><td>Pin 8 - warning LED plus</td><td>Yellow/red</td></tr></table> Now insert the plug into the gauge. Note the inverse polarity protection nose in the process.			Pin 1 - Term. 15 - ignition plus 12 V	Red	Pin 2 - Term. 31 - ground	Black	Pin 3 - unassigned	Blue/black	Pin 4 - Term. 30 - steady power	Brown	Pin 5 - unassigned	Green	Pin 6 - Term. 58 - lighting	Blue/red	Pin 7 - warning LED ground	Yellow/Black	Pin 8 - warning LED plus	Yellow/red
Pin 1 - Term. 15 - ignition plus 12 V	Red																			
Pin 2 - Term. 31 - ground	Black																			
Pin 3 - unassigned	Blue/black																			
Pin 4 - Term. 30 - steady power	Brown																			
Pin 5 - unassigned	Green																			
Pin 6 - Term. 58 - lighting	Blue/red																			
Pin 7 - warning LED ground	Yellow/Black																			
Pin 8 - warning LED plus	Yellow/red																			

Voltmeter 24 Volt	B000049	11/18 GB	4
-------------------	---------	-------------	---

12



Connector set, 8-pin - A2C59510850

Use the following connector to connect the instrument: Connector set, 8-pin - A2C59510850
The connector set is designed for a cable cross-section of 0.25 - 0.5 mm².
For other cross-sections, please use contacts made by Tyco.
Single contacts: Tyco No. 1355718-1 for 0.14 – 0.22 mm²
Tyco No. 963729-1 for 0.5 – 0.75 mm²
Strip: Tyco No. 1355717-1 for 0.14 – 0.22 mm²
Tyco No. 963715-1 for 0.5 – 0.75 mm²
Create a crimp connection using the contacts and the corresponding cables. Follow the instructions of the hand pliers manufacturer.
Use the following for this:
Hand pliers Tyco No. 539635-1
And the tool Tyco No. 539682-2 for these hand pliers
Pay special attention to whether the crimp barrel clutches all individual wires in the cable, otherwise you risk a short circuit!



Electrical connection:

- Note cable cross-sectional area!
- Reducing the cable cross-sectional area leads to higher current density, which can cause the cable cross-sectional area in question to heat up!
- When installing electrical cables, use the provided cable ducts and harnesses; however, do not run cables parallel to ignition cables or to cables that lead to large electricity consumers.
- Fasten cables with cable ties or adhesive tape. Do not run cables over moving parts. Do not attach cables to the steering column!
- Ensure that cables are not subject to tensile, compressive or shearing forces.
- If cables are run through drill holes, protect them using rubber sleeves or the like.
- Use only one cable stripper to strip the cable. Adjust the stripper so that stranded wires are not damaged or separated.
- Use only a soft soldering process or commercially available crimp connector to solder new cable connections!
- Make crimp connections with cable crimping pliers only. Follow the safety instructions of the tool manufacturer.
- Insulate exposed stranded wires to prevent short circuits.
- Caution: Risk of short circuit if junctions are faulty or cables are damaged.
- Short circuits in the vehicle network can cause fires, battery explosions and damages to other electronic systems. Consequently, all power supply cable connections must be provided with weldable connectors and sufficiently insulated.
- Ensure ground connections are sound.
- Faulty connections can cause short circuits. Only connect cables according to the electrical wiring diagram.
- If operating the instrument on power supply units, note that the power supply unit must be stabilized and it must comply with the following standard: DIN EN 61000, Parts 6-1 to 6-4.

13


Designations in the wiring diagram:

30 - terminal 30 - steady power
15 - terminal 15 - connected (ignition) plus 12 V
58 - terminal 58 - lighting


You must comply with the wiring diagram.

31 - terminal 31 - ground
F1 - fuse 5A quick-response
C1 - 8-pin MQS connector

Connection 12 V Warning contact minus, connected



Connection 12 V Warning contact plus, connected



Voltmeter 24 Volt		B000049	11/18	5
			GB	
14		Align the instrument and hand-tighten the fastening nut. Ensure that the nut is not tightened with a torque greater than 400 Ncm. * Make sure the seal lays flat between the panel and the front ring.		
15		If you would like to omit the fastening nut, you may use the part set A2C59510854 as an alternative. This is recommended if the installation location is subject to vibratory loads. Screw the stud bolts into the provided drill holes in the enclosure. Max. stud bolt torque is 1.5 Nm.		
16		Place the bracket on the stud bolt and hand-tighten the knurled nut. * Make sure the seal lays flat between the panel and the front ring (see Fig. 14).		
17		Reconnect the battery after inspecting the connection. Please note that when you disconnect the battery, all volatile electronic memories lose their input values and must be reprogrammed.		
18		If necessary, replace the main circuit switch. Turn on the ignition and conduct a functional test. Reprogram any other instruments that may have lost their saved settings.		
19	Important: Clean the instrument glass and front frame with water only. Do not use chemical agents.			
20	Accessories / Spare parts			
Bush contacts 0.25 – 0.5 mm²	A2C59510846	Flush mount seal	A2C5321564001	
Bush housing, 8-pin	A2C59510847	Fastening nut	A2C5300739801	
Bracket assembly mounting set	A2C59510854	Front ring, flat; black	A2C5318604001	
Flush mount fixing bracket	A2C59510864	Front ring, flat; white	A2C5318602201	
Adapter Cable	A2C59512947	Front ring, flat; chrome	A2C5318602301	
Make Point Switch	A2C59510886	Front ring, triangular; black	A2C5318602401	
		Front ring, triangular; white	A2C5318602501	
		Front ring, triangular; chrome	A2C5318602601	
		Front ring, round; black	A2C5318602701	
		Front ring, round; white	A2C5318602801	
		Front ring, round; chrome	A2C5318602901	
		Warning point control	A2C5951088601	
		Protective connector cap, 8-pin	A2C5332466401	
		Spinlock nut 52mm	A2C5205947101	